



TAMILNADU FIRE & RESCUE SERVICE DEPARTEMENT

RC.No: 2754/A/2021
Date : 04.05.2021

Office of the District Officer,
Fire and Rescue Services Department,
Kanchipuram District, Kanchipuram.

NO OBJECTION CERTIFICATE

Sub: Fire & Rescue Services, Kancheepuram District-Issue of No Objection Certificate for M/s.Sri Chandrasekharendra Saraswathi Viswa Mahavidyalaya, (Deemed to be University), Enathur, Kanchipuram District - Regarding.


Ref: 1) Registrar, M/s.Sri Chandrasekharendra Saraswathi Viswa Mahavidyalaya,
Letter, Dated: 04.03.2021
2) Station officer, Kanchipuram Inspection Report No.235/2021, Dated:21.04.2021

With reference to the letter cited above, Station officer, Kanchipuram has inspected the site situated at Survey Numbers 748/1, 748/2A1, 748/2B, 748/4, 749/2, 749/3, 750/3A1, 750/3A2, 750/3B, 753/1A, 753/1B, 754/1A, 754/1B1, 754/1B2, 754/1B3, 754/1B4, 754/1B5, 754/2A, 754/2B, 754/2C1, 754/2C2, 755/2C, 755/2D, 755/3 Enathur Village, Kanchipuram Taluk & District on 20.04.2021. This is a planning proposal proposed to construct M/s.Sri Chandrasekharendra Saraswathi Viswa Mahavidyalaya, (Deemed to be University) consists of (G+3) with a maximum height of 18.30Mtr. The proposed building is classified as Group - B Educational Buildings Subdivision B2 all other Institution as per the National Building Code of India-2016 Part-IV Fire and Life safety.

The following fire safety measures should be provided in the proposed building before the actual occupation as listed below.

- Fire Extinguishers should be provided as per IS 2190:2010 requirements.
- Along with Hose Reel Assembly, Down Comer system should be provided per 1000 sq.mt.,
- Manually operated fire alarm system should be provided near to exits.
- Terrace level fire water tank 20,000 liters capacity should be provided.
- One electrical pump of each capacity 450 LPM should be provided.
- Fire service inlets should be provided near the entry gate.

Office Seal



To: M/s.Sri Chandrasekharendra Saraswathi Viswa Mahavidyalaya,
(Deemed to be University)
Enathur Village, Kanchipuram Taluk & District.

District Officer,
Fire & Rescue Services,
Kanchipuram.

27.4.2021

Copy to: The Deputy Director, Fire and Rescue Services, North-Western Region, Vellore.

G. Srinivasan
REGISTRAR
S.C.S.V.M.V
ENATHUR, KANCHIPURAM

SAI SANJAY SAFETY PRODUCTS

NO: 480, METTU STREET, MORAI VIA, AVADI IAF,
VEERAPURAM, CHENNAI-600055.PH: 044- 26840113

MOBILE: 9840955043 / 8124656189

EMAIL:saisanjaysafety@gmail.com

AN ISO 9001: 2015 CERTIFIED COMPANY

GST NO: 33ATWPG4055C2ZR



FIRE EXTINGUISHER CERTIFICATE

DATE: 26.02.2021

TO:

**SRI CHANDRASEKHARENDRA SARASWATHI VISWA
MAHAVIDYALAYA**

SRI JAYENDRA SARASWATHI STREET, ENATHUR, KANCHIPURAM-631561.

SUB: CERTIFICATE OF REFILLING FOR FIRE EXTINGUISHER. .

Respected Sir,

This is inform you that as per our visit made on 26th February 2021.
We certified that they had all necessary and required FIRE SAFETY
EQUIPMENTS are fixed properly to the assigned locations. There is
adequate fire safety measures also.

This is to certify that, we were SERVICED AND REFILLED for below
mentioned FIRE EXTINGUISHERS.


REGISTRAR
S.C.S.V.M.V
ENATHUR, KANCHIPURAM

SAI SANJAY SAFETY PRODUCTS

NO: 480, METTU STREET, MORAI VIA, AVADI IAF,
VEERAPURAM, CHENNAI-600055.PH: 044- 26840113
MOBILE: 9840955043 / 8124656189

EMAIL:saisanjaysafety@gmail.com

AN ISO 9001: 2015 CERTIFIED COMPANY

GST NO: 33ATWPG4055C2ZR



S.NO	DESCRIPTION	QUANTITY	REFILLING DATE	NEXT REFILLING DATE	REMARKS
01	ABC TYPE FIRE EXTINGUISHER - 2KGS	02 NOS	26.02.2021	25.02.2023	GOOD CONDITION
02	ABC TYPE FIRE EXTINGUISHER - 5 KGS	20 NOS	26.02.2021	25.02.2023	GOOD CONDITION
03	ABC TYPE FIRE EXTINGUISHER- 6 KGS	96 NOS	26.02.2021	25.02.2023	GOOD CONDITION
04	ABC TYPE FIRE EXTINGUISHER - 9 KGS	01 NO	26.02.2021	25.02.2023	GOOD CONDITION
05	CO2 TYPE FIRE EXTINGUISHER - 2 KGS	22 NOS	26.02.2021	25.02.2023	GOOD CONDITION
06	DCP TYPE FIRE EXTINGUISHER - 5 KGS	29 NOS	26.02.2021	25.02.2023	GOOD CONDITION
07	DCP TYPE FIRE EXTINGUISHER 10 KGS	18 NOS	26.02.2021	25.02.2023	GOOD CONDITION
08	DCP TYPE FIRE EXTINGUISHER - 25 KGS	02 NOS	26.02.2021	25.02.2023	GOOD CONDITION
09	WATER TYPE FIRE EXTINGUISHER - 9LTR	01 NO	26.02.2021	25.02.2022	GOOD CONDITION

FOR SAI SANJAY SAFETY PRODUCTS

AUTHORIZED SIGNATORY

REGISTRAR
S.C.S.V.M.V
ENATHUR, KANCHIPURAM